



CERTIFIED TESTING LABORATORIES, INC.

CLIENT: Peninsula Compost Company, LLC  
612 Christiana Avenue  
Wilmington, DE 19801

DATE: 06/23/11

PROJECT: Quality Control – Wilmington, DE

LAB NO.: B-1608-11

ON SAMPLE OF: Topsoil Material

REPORT NO.: AG-2

RECEIVED: 06/10/11

SAMPLED BY: Client

MARKED: Blend sample (75% sandy fill, 25% compost)

EXAMINED WITH THE FOLLOWING RESULTS:

1. Grain size analysis (ASTM D422) Material finer than the #200 (ASTM D-1140)

<u>Sieve Size</u>	<u>% Passing</u>	<u>*Sandy Loam</u>
3/4"	100.0	
3/8"	95.8	Hydro Analysis per ASTM D422
#4	92.6	% Gravel – 9.7
#10	90.3	% Sand – 56.0
#40	68.1	% Silt – 19.8
#60	52.6	% Clay – 14.5
#100	44.3	
#200	40.9	

2. pH Value (ASTM D4972): 7.3

3. % Organics (ASTM D2974): 19.0

Respectfully Submitted  
CERTIFIED TESTING LABORATORIES, INC.

  
Terry Kifer, General Manager

TK/rs

All reports are the confidential property of clients, and information contained may not be published or reproduced, pending our written approval.